



- RAMP NOTES:**
1. PLACE RAMPS AT ALL LOCATIONS SHOWN ON PLANS OR AS DIRECTED BY PROJECT ENGINEER.
 2. THE SLOPE OF THE RAMP PROPER SHALL NOT EXCEED 1:12, 1" RISE IN A 12" SPAN.
 3. CONCRETE FOR RAMPS SHALL BE CLASS "M2" MEETING THE REQUIREMENTS AS STATED IN SPECIFICATIONS UNDER SECTION 706 OF THE LAFAYETTE CONSOLIDATED GOVERNMENT STANDARD SPECIFICATIONS, LATEST EDITION.
 4. THICKNESS OF CONCRETE WITHIN RAMP AREA TO BE 6".
 5. PROVIDE TACTILE WARNING SURFACE ON RAMPS (NO DIRECT PAY).
 6. GUTTER LINE TO BE MAINTAINED ALONG RAMP CURB OPENING AT CORNER RAMPS AND RAMP ADJACENT CURB.
 7. LANDING AT STREET CROSSINGS SHALL PROVIDE AN AREA OF TACTILE WARNING CONSISTING OF TRUNCATED DOMES. AREA OF TRUNCATION SHALL BE 2' (TWO) FEET WIDE AND EXTEND A MIN. OF 4' (FOUR) FEET OR THE FULL WIDTH OF LANDING.
 8. SIDEWALK TRANSITION SECTIONS SHALL HAVE A TACTILE WARNING TREATMENT, IN ADDITION TO THE BRUSHED FINISH, FOR A DISTANCE OF 5' FROM THE END OF THE SIDEWALK AT ALL LOCATIONS THAT DO NOT CONNECT TO EXISTING SIDEWALKS AT NO ADDITIONAL COST TO THE OWNER.